

設備名稱：無熔線斷路器，型號（型式）：NZMB1 Equipment nameType designation (Type)						
NZMB1,3P,In20/25/32/40/50/63/80/100/125/160A,Ue=230V,380V,440V,Ui800V,Uimp6kV,50/60Hz,16 OAF,Icu 30KA 230V,25KA 380V,25KA 440V,Ics=Icu,Iso 6.25KA 254V						
單元Unit	限用物質及其化學符號 Restricted substances and its chemical symbols					
	鉛Lead (Pb)	汞Mercury (Hg)	鎘Cadmium (Cd)	六價鉻 Hexavalent chromium (Cr ⁺⁶)	多溴聯苯 Polybrominated biphenyls (PBB)	多溴二苯醚 Polybrominated diphenyl ethers (PBDE)
塑膠外殼	○	○	○	○	○	○
操作機構	○	○	○	○	○	○
接續端子	○	○	○	○	○	○
內部接點	○	○	○	○	○	○
電路板	○	○	○	○	○	○
比流器	○	○	○	○	○	○
消弧室	○	○	○	○	○	○
備考1. “超出0.1 wt %” 及 “超出0.01 wt %” 係指限用物質之百分比含量超出百分比含量基準值。 Note 1 : “Exceeding 0.1 wt %” and “exceeding 0.01 wt %” indicate that the percentage content of the restricted substance exceeds the reference percentage value of presence condition.						
備考2. “○” 係指該項限用物質之百分比含量未超出百分比含量基準值。 Note 2 : “○” indicates that the percentage content of the restricted substance does not exceed the percentage of reference value of presence.						
備考3. “—” 係指該項限用物質為排除項目。 Note 3 : The “—” indicates that the restricted substance corresponds to the exemption.						